

MIDI POWER CONTROL SYSTEM

PRECISION CIRCUITS INC

WIRING DIAGRAM

10-30-2015

Cedar Creek, Riverstone, Cottage

Exact Location of Breakers not Critical
As long as Current Sensor screw terminals
L1 & L2 are on opposite phases of Line Voltage.

Part #: 00-10050-352
Reference ID: 352 3AC 5.5KGEN153
Program Options:
Relay Shed Order:
5-A/C-MID
4-A/C-FRT
3-A/C-RR
50A Service = Sleep Mode
GEN =45A Current Limit
Shed Loads

